



Punjab Biotechnology Incubator

(A State Government Undertaking)

A Component of Agri Food Biotechnology Cluster, Knowledge City, Mohali

BIS Approved | FSSAI Empanelled | EIC Approved | APEDA Approved | PPCB Approved | Notified State Water Lab - GOP | Notified Under EPA - GOI

No.PBTIFA0/060617/000686

Dated :

TEST REPORT

Sample Registration No. : PBTIFA0/060617/000686
Sample code given by customer : Drinking Water Area

Issued to:

Dikshant International School
Dhakoli,

Zirakpur
Punjab

SAMPLE PARTICULARS

Your Ref No : Email Dt. 10/08/2022 & 11/08/2022
Date & Time of Sample Collection : 18/08/2022 at 3:20pm
Date & Time of Sample Receipt in Lab : 18/08/2022 at 5:00pm
Sample Identification No. : PBTI/060617/01 A,B,C,D, Dt.18/08/2022
Site of Sample Collection : Dikshant International School, Zirakpur
Name/Nature of sample : **Drinking Water**
Type of Sample : Grab
Point of Sample Collection : Outlet (After Water Cooler)
Condition of the sample on Receipt : Intact coded sample under refrigerated condition
Qty/Pkg. : 8L approx. in plastic & glass bottles
Sampling Method : Sample drawn by PBTi as per APHA guidelines
Test Start Date : 19/08/2022
Test Completion Date : 22/08/2022

Dr. Ajit Dua

Quality Manager-cum-Technical Head

Authorized Signatory

Punjab Biotechnology Incubator

Note:

1. The above results pertain only to the sample tested.
2. The report shall not be used for advertising or any legal purpose without written permission from the Chief Executive Officer, Punjab Biotechnology Incubator
3. This report cannot be re-produced, except when in full, without the written permission from the Chief Executive Officer, Punjab Biotechnology Incubator
4. Perishable samples will be destroyed after testing, others after one month from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations

Format No : PBTI/F/5.10/04
Revision No. 00

Page No. 1/2

SCO: 7&8, Phase-V, SAS Nagar (Mohali) - 160 059, Punjab, India

Phone: +91 172-5020893, 5093595, 5053094, 5020895, Tele. Fax : +91 172-5020895

E-mail : pbt2005@yahoo.com; Website : www.pbttilabs.com

Sample Registration No

PBT/FA0/060617/000686

Sample code given by customer

Drinking Water Area

Test Results

S No.	Parameter	Requirement (Desirable Limit) As per IS 10500 : 2012)	Results	Units	Test Method
1	Color	Max 5	0.5	Hazen	IS 3025 (Part 4)
2	Odour	Agreeable	Agreeable		IS 3025 (Part 5)
3	pH	6.5-8.5	7.66		IS 3025 (Part 11)
4	Taste	Agreeable	Agreeable		IS 3025 (Part 8)
5	Turbidity	Max 1	0.10	NTU	IS 3025 (Part 10)
6	Chloride (as Cl)	Max 250	13.5	mg/l	IS 3025 (Part 32)
7	Fluoride (as F)	Max 1	0.35	mg/l	IS 3025 (Part 60) by Spectrophotometer
8	Residual free chlorine	Min 0.2 (For chlorinated supplies)	BDL (MDL 0.1)	mg/l	IS 3025 (Part 26)
9	Iron (as Fe)	Max 1	BDL (MDL 0.01)	mg/l	APHA 3125 B (By ICP-MS)
10	Hardness Total (as CaCO ₃)	Max 200	116	mg/l	IS 3025 (Part 21)
11	E. coli (or thermotolerant Coliform bacteria)	Not Detectable	Not Detectable	MPN/100 ml	IS 1622
12	Coliform bacteria	Not Detectable	Not Detectable	MPN/100 ml	IS 1622



Dr. Ajit Dua
Quality Manager-cum-Technical Head
Authorized Signatory
Punjab Biotechnology Incubator

Notes:

1. The above results pertain only to the sample tested.
2. The report shall not be used for advertising or any legal purpose without written permission from the Chief Executive Officer, Punjab Biotechnology Incubator.
3. This report cannot be re-produced, except when in full, without the written permission from the Chief Executive Officer, Punjab Biotechnology Incubator.
4. Psychiatric samples will be destroyed after testing, others after one month from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Format No. PBT/FA/5 10/04
Revision No. 00

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


Date: 10-10-2022

It is Certified that an inspection Team headed by Mr.Rajinder Singh

(Name of Officers with Designation) from CHIEF SANITARY INSPECTOR (Name of the Department/Office) inspected Dikshant International School, Dhakoli (Name & Address of the School) on 10-10-2022 and found that the Dikshant International School (Name of school) has safe Drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the Campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 10-10-2022 to 09-10-2023

**Chief Sanitary Inspector
Municipal Council, Zirakpur**

Signatures with Seal: 

Name :RAJINDER SINGH

Designation: CHIEF SANITARY INSPECTOR

MUNICIPAL COMMITTEE ZIRAKPUR

TO

Dikshant International School
Dhakoli, Zirakpur

(Name&Address of the Institution)